

ICC-ES Evaluation Report

ESR-1082

Reissued February 2025


This report also contains:

- [City of LA Supplement](#)
- [CA Supplement](#)
- [FL Supplement w/HVHZ](#)

Subject to renewal February 2027

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

Copyright © 2025 ICC Evaluation Service, LLC. All rights reserved.

<p>DIVISION: 06 00 00— WOOD, PLASTICS AND COMPOSITES</p> <p>Section: 06 17 53— Shop-Fabricated Wood Trusses</p>	<p>REPORT HOLDER: EAGLE METAL PRODUCTS</p>	<p>EVALUATION SUBJECT: EAGLE METAL PRODUCTS EAGLE 20, EAGLE 18, EAGLE 20HS, EAGLE 18HS, EAGLE 18HSX, AND EAGLE 18 HINGE PLATE CONNECTOR TRUSS METAL CONNECTOR PLATES</p>	
---	--	--	---

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2024, 2021, 2018, 2015, 2012, 2009 and 2006 [International Building Code® \(IBC\)](#)
- 2024, 2021, 2018, 2015, 2012, 2009 and 2006 [International Residential Code® \(IRC\)](#)

Property evaluated:

- Structural

2.0 USES

The Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX, and Eagle 18 Hinge Plate Connector truss metal connector plates are used as joint connectors of light-framed wood roof and floor trusses.

3.0 DESCRIPTION

3.1 Eagle 20:

Eagle 20 truss metal connector plates are manufactured from minimum No. 20 gage [0.0356 inch (0.904 mm) total thickness], ASTM A653, SS designation, Grade 40, structural steel with a G60 galvanization coating [0.0005 inch (0.013 mm) thickness each side] with base-metal thickness of 0.0346 inch (0.878 mm). Each plate has nominally 1/8-inch-wide (3.2 mm), 1/2-inch-long (12.7 mm) teeth that are stamped in pairs and bent at right angles from the face of the plate. The teeth are nominally spaced 1 inch (25.4 mm) on center along the length, and 1/4 inch (6.4 mm) on center along the width and are staggered 3/32 inch (2.38 mm) off center. Each plate has eight teeth per square inch (1.24 teeth/cm²). See [Figure 1](#) for details.

3.2 Eagle 18:

Eagle 18 truss metal connector plates are manufactured from minimum No.18 gage [0.0466 inch (1.184 mm) total thickness], ASTM A653, SS designation, Grade 40, structural steel with a minimum G60 galvanization coating [0.0005 inch (0.013 mm) thickness each side] with base-metal thickness of 0.0456 inch (1.158 mm). Eagle 18 truss metal connector plates are stamped identically to the Eagle 20 truss metal connector plates. See [Figure 1](#) for details.

3.3 Eagle 20HS:

Eagle 20HS truss metal connector plates are manufactured from minimum No. 20 gage [0.0356 inch (0.904 mm) total thickness], ASTM A653, HSLAS designation, Grade 60, structural steel with a G60 galvanization coating [0.0005 inch (0.013 mm) thickness each side] with base-metal thickness of 0.0346 inch (0.878 mm). Each plate has nominally $\frac{1}{8}$ -inch-wide (3.2 mm), $\frac{1}{2}$ -inch-long (12.7 mm) teeth that are stamped in pairs and bent at right angles from the face of the plate. The teeth are nominally spaced 1 inch (25.4 mm) on center along the length, and $\frac{1}{4}$ inch (6.4 mm) on center along the width and are staggered $\frac{3}{32}$ inch (2.4 mm) off center. Each plate has six teeth per square inch (1.24 teeth/cm²), and every fourth row is removed. See [Figure 2](#) for details.

3.4 Eagle 18HS:

Eagle 18HS truss metal connector plates are manufactured from minimum No. 18 gage [0.0466 inch (1.184 mm) total thickness], ASTM A653, HSLAS designation, Grade 60, structural steel with a G60 galvanization coating [0.0005 inch (0.013 mm) thickness each side] with base-metal thickness of 0.0456 inch (1.158 mm). Eagle 18HS truss metal connector plates are stamped identically to the Eagle 20 truss metal connector plates. See [Figure 1](#) for details.

3.5 Eagle 18HSX:

Eagle 18HSX truss metal connector plates are manufactured from minimum No. 18 gage [0.0466 inch (1.184 mm) total thickness], ASTM A653, HSLAS designation, Grade 60, structural steel with a G60 galvanization coating [0.0005 inch (0.0127 mm) thickness each side] with base-metal thickness of 0.0456 inch (1.158 mm). Each plate has nominally $\frac{1}{8}$ -inch-wide (3.2 mm), $\frac{1}{2}$ -inch-long (12.7 mm) teeth that are bent at right angles from the face of the plate. Rows of teeth are spaced nominally 1 inch (25.4 mm) on center along the length, and $\frac{1}{4}$ inch (6.35 mm) on center along the width. Each plate has four teeth per square inch (0.62 teeth/cm²). See [Figure 3](#) for details.

3.6 Eagle 18 Hinge Plate Connector:

The Eagle 18 Hinge Plate Connector is manufactured from two metal connector plates, stamped from minimum No. 18 gage [0.0466 inch (1.184 mm) total thickness], ASTM A653, SS designation, Grade 40, structural steel with a G60 galvanization coating [0.0005 inch (0.013 mm) thickness each side] with base-metal thickness of 0.0456 inch (1.158 mm). The two plates are overlapped by 2 inches (38.1 mm) and factory-connected by a grommet placed in a pre-punched hole in each plate. Overall, the hinge plate measures $2\frac{1}{4}$ inches wide by $8\frac{3}{8}$ inches long (57 mm by 213 mm). Each metal connector plate section is composed of 60 individual teeth for a total of 120 teeth per hinge plate connector. See [Figure 4](#) and [Figure 5](#) for details.

4.0 INSTALLATION

4.1 General:

All truss metal connector plates must be pressed into the wood for the full depth of their teeth by hydraulic-platen embedment presses, multiple roller presses that use partial embedment followed by full-embedment rollers, or combinations of partial embedment roller presses and hydraulic-platen presses that feed trusses into a stationary finish roller press. Trusses must be assembled within the tolerances provided by the Truss Plate Institute (TPI) Quality Criteria for Metal Plate Connected Wood Trusses, shown in Chapter 4 Metal Connector Plate Manufacturing of ANSI/TPI 1-2022, National Design Standard for Metal Plate Connected Wood Truss Construction.

4.2 Allowable Design Values:

4.2.1 Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, and Eagle 18HSX: Allowable design values for these Eagle Metal Products truss metal connector plates to be used in the design of metal-plate-connected wood roof and floor trusses are shown in [Tables 1](#) and [2](#). Allowable design values are applicable when the connection is made with identical plates on opposite sides of the joint.

4.2.2 Eagle 18 Hinge Plate Connector: The allowable design values of Eagle 18 Hinge Plate Connectors in shear, tension and compression are shown in [Table 3](#). Imposed forces at the joint and within the truss containing the joint must be determined using a structural model with a pin at the hinge joint location. Allowable design values are applicable when the connection is made with a 1-inch (25.4 mm), or smaller, gap between the two wood members at the connection. The design load due to combined shear and axial loads must not exceed the allowable load using the Hankinson formula as follows:

$$F_e \leq P_e$$

where:

F_{θ} = Imposed combined shear and axial load, lb, = $(F_a^2 + F_v^2)^{0.5}$.

P_{θ} = Allowable combined shear and axial load, lb, = $(P_a \times P_v) / ((P_a \times (\sin \theta)^2) + (P_v \times (\cos \theta)^2))$.

F_a = Imposed axial force, lb.

F_v = Imposed shear force, lb.

P_a = Allowable axial force, lb. (in compression or tension corresponding to imposed axial force).

P_v = Allowable shear load, lb.

Θ = Angle between F_{θ} and the length of the plate.

5.0 CONDITIONS OF USE:

The Eagle Metal Products truss metal connector plates described in this report comply with, or are suitable alternatives to what is specified in, those codes specifically listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 This evaluation report and the installation instructions, when required by the code official, must be submitted at the time of permit application. In the event of a conflict between the manufacturer's published installation instructions and this report, this report governs.
- 5.2 Each application for a building permit using these truss metal plate connectors must be accompanied by calculations, details and other documentation showing that the design, manufacture, and proposed installation conforms with the requirements of the applicable code. The calculations must be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.3 This report establishes plate design values only. For items not covered by this report, such as truss design, fabrication, quality assurance and special inspection, refer to ANSI/TPI 1, engineering drawings and the applicable code.
- 5.4 The design values used in the design of trusses using Eagle Metal Products truss metal connector plates must not exceed those listed in [Tables 1, 2 and 3](#). Load combination reductions must be in accordance with the applicable code.
- 5.5 All lumber used in the fabrication of trusses using Eagle Metal Products wood truss metal connector plates must be graded in compliance with the applicable code and must have a moisture content not to exceed 19 percent at the time of assembly. Wet service factors from ANSI/TPI 1 must be applied to the table values when the lumber moisture content exceeds 19 percent. Allowable design values shown in the tables of this report are not applicable to metal connector plates embedded in either fire-retardant-treated lumber or preservative-treated lumber.
- 5.6 Truss metal connector plates must be installed in pairs on opposite faces of truss members.
- 5.7 Use in corrosive conditions defined by ANSI/TPI 1 Section 6.5 is outside the scope of this report.
- 5.8 The following conditions apply to the Eagle 18 Hinge Plate Connector only:
 - 5.8.1 Allowable load values for the Eagle 18 Hinge Plate Connectors are applicable to hinge plate pairs installed on opposite faces and positioned in the 180-degree (unbent) position in the final installation of the truss.
 - 5.8.2 The allowable compression load given in [Table 3](#) is valid for applications where sheathing is attached to the truss chord members containing the metal hinge plate connectors, and lateral translation across the joint is inhibited by the sheathing being installed continuously across the joint as prescribed by code, or by other means acceptable to the code official. Eagle 18 Hinge Plate Connectors must not be used to transfer any loads in a direction perpendicular to the plane of the truss, such as for design of load transfer at joints of unblocked diaphragms.
 - 5.8.3 Due to the rotation provided at the joint of the Eagle 18 Hinge Plate Connector, the truss design must be modeled with a pin at the hinge joint location. In the final installed condition, shear loads must be applied within the plane of the hinge plate, at a 90-degree angle to the long axis.
 - 5.8.4 Design of diaphragms with trusses manufactured with the Eagle 18 Hinge Plate Connector is outside the scope of this report.
 - 5.8.5 Allowable design values given in [Table 3](#) for Eagle 18 Hinge Plate Connectors are applicable when the connection is made with a 1-inch (25.4 mm), or smaller, gap between the two wood members at the connection.

- 5.8.6 Use of the Eagle 18 Hinge Plate Connector is limited to prefabricated trusses. Field installation is prohibited.
- 5.9 This evaluation report is limited to the evaluation of connection capacity of the Eagle Metal Products truss metal connector plates covered in this report. The design, manufacture, and installation of trusses employing the truss metal connector plates have not been evaluated and must comply with IBC Section 2303.4 (Section 2303.4.2 under the 2006 IBC) or IRC Sections R502.12 (R502.11 under the 2021, 2018, 2015, 2012, 2009 and 2006 IRC) and R802.10.

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with ANSI/TPI 1-2022, National Design Standard for Metal Plate Connected Wood Truss Construction.
- 6.2 Manufacturer's descriptive literature.
- 6.3 Quality documentation.
- 6.4 Data in accordance with the [ICC-ES Acceptance Criteria for Metal Hinge Plate Connectors for Wood Trusses \(AC283\)](#), dated November 2015 (editorially revised February 2024).

7.0 IDENTIFICATION

- 7.1 The ICC-ES mark of conformity, electronic labeling, or the evaluation report number (ICC-ES ESR-1082) along with the name, registered trademark, or registered logo of the report holder must be included in the product label.
- 7.2 In addition, each Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Hinge Plate Connector truss metal connector plate 3 inches (76.2 mm) in width or wider, and 25 percent of plates less than 3 inches (76.2mm) in width, are identified by an embossed "EAGLE20" for the Eagle 20, "EAGLE18" for the Eagle 18, "EAGLE20HS" for the Eagle 20HS, "EAGLE18HS" for the Eagle 18HS, "EAGLEHSX" for the Eagle 18HSX, and "EAGLE18" for the Eagle 18 Hinge Plate Connector; and/or the same designations in a fast-drying permanent ink application. Additionally, boxes containing the Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Hinge Plate Connector truss metal connector plates must bear the name of the connector (Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX, or Eagle 18 Hinge Plate Connector).
- 7.3 The report holder's contact information is as follows:

EAGLE METAL PRODUCTS
11511 LUNA ROAD #100
DALLAS, TEXAS 75234
(972) 350-9805
www.eaglemetal.com

TABLE 1 - LATERAL RESISTANCE ALLOWABLE DESIGN VALUES [PSI/PLATE]

LUMBER SPECIES	SG	AA	EA	AE	EE
EAGLE 20, EAGLE 18, & EAGLE 18HS					
SOUTHERN PINE	0.55	222	185	160	168
SPRUCE-PINE-FIR	0.42	170	141	122	128
HEM-FIR	0.43	170	141	122	128
DOUGLAS-FIR-LARCH	0.50	222	185	160	168
EAGLE 20HS					
SOUTHERN PINE	0.55	167	139	120	126
SPRUCE-PINE-FIR	0.42	127	106	92	96
HEM-FIR	0.43	127	106	92	96
DOUGLAS-FIR-LARCH	0.50	167	139	120	126
EAGLE 18HSX					
SOUTHERN PINE	0.55	111	93	80	84
SPRUCE-PINE-FIR	0.42	85	71	61	64
HEM-FIR	0.43	85	71	61	64
DOUGLAS-FIR-LARCH	0.50	111	93	80	84

- AA** Plate Parallel to load, wood grain parallel to load.
- EA** Plate perpendicular to load, wood grain parallel to load.
- AE** Plate parallel to load, wood grain perpendicular to load.
- EE** Plate perpendicular to load, wood grain perpendicular to load.

FOR SI: 1 PSI = 6.9 KPA.

1. TOOTH HOLDING UNITS = psi for a single plate (lb/in²/PLATE). To achieve values, plates must be installed on opposite sides of joint.
2. All truss plates are pressed into the wood for the full depth of their teeth by hydraulic-platen embedment presses, multiple roller presses that use partial embedment followed by full-embedment rollers, or combinations of partial embedment roller presses and hydraulic-platen presses that feed trusses into a stationary finish roller press.

TABLE 2 - EFFECTIVE TENSION & SHEAR ALLOWABLE DESIGN VALUES

	EAGLE 20		EAGLE 18		EAGLE 20HS		EAGLE 18HS		EAGLE 18HSX	
	ER ²	LB/IN/PR	ER ²	LB/IN/PR	ER ²	LB/IN/PR	ER ²	LB/IN/PR	ER ²	LB/IN/PR
MAX TENSION ¹ , 0°	0.60	1,050	0.61	1,395	0.66	1,683	0.57	1,917	0.89	3,035
MAX TENSION ¹ , 90°	0.47	822	0.47	1,085	0.54	1,377	0.54	1,819	0.88	3,003
MIN TENSION ¹ , 0°	0.48	836	0.48	1,104	0.59	1,503	0.52	1,735	0.64	2,206
MIN TENSION ¹ , 90°	0.57	989	0.57	1,305	0.50	1,276	0.59	1,999	0.65	2,214
SHEAR, 0°	0.62	718	0.62	946	0.54	823	0.51	1,023	0.45	1,033
SHEAR, 30°	0.67	786	0.67	1,036	0.63	956	0.60	1,207	1.14	2,602
SHEAR, 60°	0.82	956	0.82	1,260	0.73	1,124	0.75	1,488	0.66	1,505
SHEAR, 90°	0.54	632	0.54	833	0.41	632	0.47	928	0.49	1,118
SHEAR, 120°	0.42	491	0.42	647	0.46	707	0.38	774	0.26	592
SHEAR, 150°	0.51	592	0.51	780	0.39	596	0.42	849	0.98	2,242

ER Efficiency Ratio

FOR SI: 1LB/IN/PR - 0.18N/MM/PR

1. Max values permissible when steel is over the joint. Steel over the joint is defined as the centerline of the solid steel is within 1/16" of the joint centerline for the 90 degree orientation and the centerline of the solid steel is within 1/4" of the joint centerline for the 0 degree orientation. Min values used when steel is not over the joint.

TABLE 3 - EAGLE 18 HINGE PLATE ALLOWABLE DESIGN VALUES

SPECIMEN LOAD TYPE	ALLOWABLE LOAD [LB/PR]
SHEAR	896
AXIAL TENSION	1,643
AXIAL COMPRESSION	1,598

FOR SI: 1LB = 4.45 N.

Values were obtained using SPF lumber with a SG = 0.42




FIGURE 1—APPROXIMATE DIMENSIONS OF EAGLE 20, EAGLE 18, EAGLE 18HS CONNECTOR PLATES




FIGURE 2—APPROXIMATE DIMENSIONS OF EAGLE 20HS CONNECTOR PLATE




FIGURE 3—APPROXIMATE DIMENSIONS OF EAGLE 18HSX CONNECTOR PLATE




FIGURE 4—APPROXIMATE DIMENSIONS OF EAGLE 18 HINGE CONNECTOR PLATE




FIGURE 5—EAGLE 18 HINGE CONNECTOR PLATE IN ARTICULATED POSITION

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES
Section: 06 17 53—Shop-Fabricated Wood Trusses

REPORT HOLDER:**EAGLE METAL PRODUCTS****EVALUATION SUBJECT:****EAGLE METAL PRODUCTS EAGLE 20, EAGLE 18, EAGLE 20HS, EAGLE 18HS, EAGLE 18HSX AND EAGLE 18 HINGE PLATE CONNECTOR TRUSS METAL CONNECTOR PLATES****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Hinge Plate Connector Truss Metal Connector Plates, described in ICC-ES evaluation report [ESR-1082](#), have also been evaluated for compliance with the codes noted below as adopted by the Los Angeles Department of Building and Safety (LADBS).

Applicable code editions:

- 2023 *City of Los Angeles Building Code* ([LABC](#))
- 2023 *City of Los Angeles Residential Code* ([LARC](#))

2.0 CONCLUSIONS

The Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Hinge Plate Connector Truss Metal Connector Plates, described in Sections 2.0 through 7.0 of the evaluation report [ESR-1082](#), comply with LABC Chapter 23, and LARC, and are subjected to the conditions of use described in this supplement.

3.0 CONDITIONS OF USE

The Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Hinge Plate Connector Truss Metal Connector Plates described in this evaluation report must comply with all of the following conditions:

- All applicable sections in the evaluation report [ESR-1082](#).
- The design, installation, conditions of use and identification are in accordance with the 2021 *International Building Code*® (IBC) and 2021 *International Residential Code*® (IRC) provisions, as applicable, noted in the evaluation report [ESR-1082](#).
- The design, installation and inspection are in accordance with additional requirements of LABC Chapters 16, 17 and 23, and LARC Sections R502 and R802, as applicable.
- The design, manufacture, and installation of trusses employing the truss metal connector plates must comply with applicable LABC, LARC and ANSI/TPI 1 provisions, such as TPI 1 Chapter 8 provisions for heel joints and provisions for loads applied at an angle with respect to lumber grain.
- Metal connector plate teeth with 1/2 inch (12.7 mm) of the ends of truss wood members must be considered ineffective to carry any load.

This supplement expires concurrently with the evaluation report, reissued February 2025.

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES
Section: 06 17 53—Shop-Fabricated Wood Trusses

REPORT HOLDER:**EAGLE METAL PRODUCTS****EVALUATION SUBJECT:****EAGLE METAL PRODUCTS EAGLE 20, EAGLE 18, EAGLE 20HS, EAGLE 18HS, EAGLE 18HSX, AND EAGLE 18 HINGE PLATE CONNECTOR TRUSS METAL CONNECTOR PLATES****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX, and Eagle 18 Hinge Plate Connector Truss Metal Connector Plates, described in ICC-ES evaluation report ESR-1082, have also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2022 California Building Code (CBC)

For evaluation of applicable chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) AKA: California Department of Health Care Access and Information (HCAI) and the Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

- 2022 California Residential Code (CRC)

2.0 CONCLUSIONS**2.1 CBC**

The Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Hinge Plate Connector Truss Metal Connector Plates, described in Sections 2.0 through 7.0 of the evaluation report ESR-1082, comply with CBC Chapter 23, provided the design and installation are in accordance with the 2021 *International Building Code*® (IBC) provisions noted in the evaluation report and the additional requirements of CBC Chapters 16, 17 and 23, as applicable.

2.1.1 OSHPD:

The applicable OSHPD Sections and Chapters of the CBC are beyond the scope of this supplement.

2.1.2 DSA:

The applicable DSA Sections and Chapters of the CBC are beyond the scope of this supplement.

2.2 CRC:

The Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Hinge Plate Connector Truss Metal Connector Plates, described in Sections 2.0 through 7.0 of the evaluation report ESR-1082, comply with CRC, provided the design and installation are in accordance with the 2021 *International Residential Code*® (IRC) provisions noted in the evaluation report and the additional requirements of CRC Chapter 3, Sections R502 and R802.

This supplement expires concurrently with the evaluation report, reissued February 2025.

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES
Section: 06 17 53—Shop-Fabricated Wood Trusses

REPORT HOLDER:

EAGLE METAL PRODUCTS

EVALUATION SUBJECT:

EAGLE METAL PRODUCTS EAGLE 20, EAGLE 18, EAGLE 20HS, EAGLE 18HS, EAGLE 18HSX AND EAGLE 18 HINGE PLATE CONNECTOR TRUSS METAL CONNECTOR PLATES

1.0 REPORT PURPOSE AND SCOPE

Purpose:

The purpose of this evaluation report supplement is to indicate that Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Metal Hinge Plate Connector Truss Metal Connector Plates, described in ICC-ES evaluation report ESR-1082, have also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2023 Florida Building Code—Building
- 2023 Florida Building Code—Residential

2.0 CONCLUSIONS

The Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Metal Hinge Plate Connector Truss Metal Connector Plates, described in Sections 2.0 through 7.0 of the evaluation report ESR-1082, comply with the *Florida Building Code—Building* and the *Florida Building Code—Residential*. The design must be in accordance with the *Florida Building Code—Building* or the *Florida Building Code—Residential*, as applicable. The installation requirements noted in ICC-ES evaluation report ESR-1082 for the 2021 *International Building Code*® (IBC) meet the requirements of the *Florida Building Code—Building* or *Florida Building Code—Residential*, as applicable.

Use of the Eagle Metal Products Eagle 20, Eagle 18, Eagle 20HS, Eagle 18HS, Eagle 18HSX and Eagle 18 Metal Hinge Plate Connector Truss Metal Connector Plates have also been found to be in compliance with the High-Velocity Hurricane Zone provisions of the *Florida Building Code—Building* and the *Florida Building Code—Residential*.

For products falling under Florida Rule 61G20-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official, when the report holder does not possess an approval by the Commission).

This supplement expires concurrently with the evaluation report, reissued February 2025.